

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

EFREN ABRATIQUÉ, P.E.
PRESIDENT

JAVIER NUÑEZ
VICE-PRESIDENT

VAN AMBATIELOS

PEDRO BIRBA

MARSHA L. BROWN

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY

201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

Anthony Forest Products Company
309 N. Washington
El Dorado, AR 71730

Attn: Kerlin Drake
(870) 862-3414

RESEARCH REPORT: RR 25381
(CSI #06180)

BASED UPON ICBO ES EVALUATION
REPORT NO. ER-5263

REEVALUATION DUE DATE:
September 1, 2008

GENERAL APPROVAL - Reevaluation - Anthony Power Beams Combinations 28F-E 1, 28F-E 2, 30F-E 1 and 30F-E 2.

DETAILS

The above assemblies and /or products are approved when in compliance with the description, use, identification and findings of Report No. ER-5263 , dated June 1, 2001, of the ICBO Evaluation Service, Incorporated. The report in its entirety, is attached and made part of this General Approval.

The parts of Report No. ER-5263 which are excluded on the attached copy have been removed by the Los Angeles City Building Department as not being included in this approval.

The Approval is subject to the following conditions:

1. Anthony Power Beams shall be manufactured by a Los Angeles City licensed fabricators.
2. Beams shall be identified by a stamp bearing the name of Anthony Forest Products, the plant location, the evaluation report number and the logo of the quality control agency, American Institute of Timber Construction (AITC).
3. Design values are noted in Table 1. The design and installation requirements for structural glued-laminated beams and connections shall comply with the 2002 Los Angeles City Building Code. Beams shall be designed and detailed by an Architect, Civil Engineer or Structural Engineer registered in the State of California.

RR 25381
Page 1 of 2

Anthony Forest Products Company
RE: Anthony Power Beams

4. Beams are not permitted to be notched or cut.

DISCUSSION:


The approval is based on test and analysis.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revision to the report must be submitted to this department, with appropriate fee, for review in order to continue the approval of the revised report.


Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

The status of the referenced Evaluation Report No. ER-5263 dated June 1, 2001, which is currently beyond its reexamination date is still valid. The validity of the evaluation report was verified with ICBO.



YEUAN CHOU, Chief
Engineering Research Section
2319 Dorris Place
Los Angeles, CA 90031
Phone (213) 485-2376
Fax (213) 847-0985

 RB:elcm
R25381wpd8.0
R07/19/06
IID/2316.2

Attachment: ICBO ES Evaluation Report ER-5263 (3 pages)

